

ENGLISH



Manual - BMV-700

Battery monitor

Rev 11 - 04/2023 This manual is also available in HTML5.

Table of Contents

1. Safety precautions	1
1.1. General safety precautions	
1.2. Battery safety warnings	
1.3. Transport and storage	1
2. Introduction	2
2.1. The battery monitor	
2.2. Why should I monitor my battery?	
2.3. Sizing	
2.5. Accessories	
	_
3. Installation	4
3.1. What's in the box?	4
3.2. Mounting the shunt	
3.3. Mounting the head unit	
3.4. Connections overview	
3.5. Basic electrical connections	
3.7. Use of alternative shunts	
3.8. GX device connection	
4. Configuration	
4.1. Setup wizard	10
4.2. Automatic voltage detection	
4.3. How to change settings	
4.3.1. Settings via the head unit	
4.3.2. The VictronConnect app	
4.4. Update firmware	
4.5. Make essential settings	
4.5.2. Set the battery capacity value	
4.5.3. Set state of charge	
4.6. Make Lithium settings (if needed)	
5. Operation	15
5.1. How does the battery monitor work?	
5.2. Readout overview	
5.3. Using the head unit menus	
5.5. History	
5.5.1. Accessing historical data via the VictronConnect app	
5.5.2. Accessing historical data via the head unit	
5.5.3. History data	
5.6. Alarms	19
5.7. Synchronising the battery monitor	
5.7.1. Automatic synchronisation	
5.7.2. Manual synchronisation	20
6. Interfacing	21
6.1. VictronConnect app via USB	21
6.2. Connecting to a GX device and the VRM portal	
6.3. Connecting to VE.Smart networking	
6.4. Custom integration	
-	
7. All features and settings	
7.1. How to change settings	
7.1.1. Accessing settings via the head unit	
7.1.2. Accessing settings via the VictronConnect app	
7.1.3. Saving, loading and sharing settings in VictronConnect	
r.z. Dallery sellings	23



		22
7.2.1. Battery capacity	•••••	23
7.2.2. Charged voltage		24
7.2.3. Discharge floor		24
7.2.4. Tail current		24
7.2.5. Charged detection time		
7.2.6. Peukert exponent		
7.2.7. Charge efficiency factor		25
7.2.8. Current threshold		
7.2.9. Time-to-go averaging period		
7.2.10. Battery starts synchronised		25
7.2.11. State of charge		26
7.2.12. Synchronise SoC to 100%		
7.2.13. Zero current calibration		
7.3. Relay settings		
7.3.1. Relay mode		26
7.3.2. Invert relay		27
7.3.3. Relay state		
7.3.4. Relay minimum closed time		
7.3.5. Relay off delay		
7.3.6. Low State of Charge (SoC) relay		27
7.3.7. Low voltage relay		
7.3.8. High voltage relay		
7.4. Alarm settings		
7.4.1. Alarm buzzer		
7.4.2. Low SoC alarm settings		29
7.4.3. Low voltage alarm		
7.4.4. High voltage alarm		
7.5. Display settings		
7.5.1. Backlight intensity		29
7.5.2. Backlight always on		29
7.5.3. Scroll speed		
7.5.4. Main voltage display		
7.5.5. Current display		30
7.5.6. Power display		30
7.5.7. Consumed An display		
7.5.7. Consumed Ah display		
7.5.8. State of charge display		30
7.5.8. State of charge display 7.5.9. Time-to-go display		30 30
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings	· · · · · · · · · · · · · · · · · · ·	30 30 31
7.5.8. State of charge display 7.5.9. Time-to-go display	· · · · · · · · · · · · · · · · · · ·	30 30 31
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 	······	30 30 31 31
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 	· · · · · · · · · · · · · · · · · · ·	30 30 31 31 31
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 	· · · · · · · · · · · · · · · · · · ·	30 30 31 31 31 31
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup	· · · · · · · · · · · · · · · · · · ·	30 30 31 31 31 31 31 31
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 	· · · · · · · · · · · · · · · · · · ·	30 30 31 31 31 31 31 31
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 	· · · · · · · · · · · · · · · · · · ·	30 30 31 31 31 31 31 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 	· · · · · · · · · · · · · · · · · · ·	30 30 31 31 31 31 31 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised		30 30 31 31 31 31 31 32 32 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 	· · · · · · · · · · · · · · · · · · ·	 30 31 31 31 31 31 32 32 32 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 		30 31 31 31 31 31 32 32 32 32 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 		30 31 31 31 31 31 32 32 32 32 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 		 30 30 31 31 31 31 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number		 30 30 31 31 31 31 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 		 30 30 31 31 31 31 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware		 30 30 31 31 31 31 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 		 30 30 31 31 31 31 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware		 30 30 31 31 31 31 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 		 30 31 31 31 31 31 32 33
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware		 30 31 31 31 31 31 32 33
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 		 30 31 31 31 31 31 32 33
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32
 7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32
 7.5.8. State of charge display		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues		30 30 31 31 31 31 31 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults		30 30 31 31 31 31 31 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.6. Reset to defaults 7.7.7.6. Reset to defaults		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9. Troubleshooting 9.1. Functionality issues 9.1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2.1. Cannot connect via Bluetooth		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues 9.1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2. Connection issues 9.2. PIN code lost		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues 9.1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2. Connection issues 9.2. PIN code lost 9.3. Incorrect readings		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9. Troubleshooting 9.1. Functionality issues 9.1.1. Unit is dead 9.2.2. Connection issues 9.2.1. Cannot connect via Bluetooth 9.2.2. PIN code lost 9.3.1. Charge and discharge current are inverted		30 30 31 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues 9.1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2. Connection issues 9.2.1. Cannot connect via Bluetooth 9.2.2. PIN code lost 9.3. Incorrect readings		30 30 31 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues 9.1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2.1. Cannot connect via Bluetooth 9.2.2. PIN code lost 9.3.1. Charge and discharge current are inverted 9.3.2. Incomplete current reading		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9. Troubleshooting 9. 1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2.2. PIN code lost 9.3.1. Charge and discharge current are inverted 9.3.3. There is a current reading while no current flows		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32
7.5.8. State of charge display 7.5.9. Time-to-go display 7.6. Miscellaneous settings 7.6.1. Software version 7.6.2. Restore defaults 7.6.3. Clear history 7.6.4. Lock setup 7.6.5. Shunt current 7.6.6. Shunt voltage 7.6.7. Battery starts synchronised 7.7. Additional settings 7.7.1. Reset history 7.7.2. Reset PIN code 7.7.3. Serial number 7.7.4. Custom name 7.7.5. Firmware 7.7.6. Reset to defaults 8. Battery capacity and Peukert exponent 9.1. Functionality issues 9.1.1. Unit is dead 9.1.2. Unable to change VictronConnect settings 9.2.1. Cannot connect via Bluetooth 9.2.2. PIN code lost 9.3.1. Charge and discharge current are inverted 9.3.2. Incomplete current reading		30 30 31 31 31 31 32 32 32 32 32 32 32 32 32 32 32 32 32



	9.3.6. State of charge does not reach 100%	
	9.3.7. State of charge always shows 100%	
	9.3.8. State of charge does not increase fast enough or too fast when charging	
	9.3.9. Incorrect battery voltage reading	
	9.3.10. Synchronisation issues	
	I data ēchnical data	
11. Appendix	٢	41
	Dimensions BMV head unitDimensions shunt	



1. Safety precautions

1.1. General safety precautions



Read this manual carefully. It contains important instructions that must be followed during installation, operation and maintenance.

Save these instructions for future reference on operation and maintenance.

1.2. Battery safety warnings



Working in the vicinity of a lead acid battery is dangerous. Batteries can generate explosive gases during operation. Never smoke or allow a spark or flame in the vicinity of a battery. Provide sufficient ventilation around the battery.

Wear eye and clothing protection. Avoid touching eyes while working near batteries. Wash your hands when done.

If battery acid contacts skin or clothing, wash them immediately with soap and water. If acid enters an eye, immediately flood the eye with running cold water for at least 15 minutes and get medical attention immediately.

Be careful when using metal tools in the vicinity of batteries. Dropping a metal tool onto a battery might cause a short circuit and possibly an explosion.

Remove personal metal items such as rings, bracelets, necklaces, and watches when working with a battery. A battery can produce a short circuit current high enough to melt objects such as rings, causing severe burns.

1.3. Transport and storage



Store this product in a dry environment.

Store this product in temperatures between -40°C and +60°C.



2. Introduction

2.1. The battery monitor

The BMV-700 is a battery monitor. It measures battery voltage and current. Based on these measurements, it calculates the battery's state of charge and the time to go. It also keeps track of historical data, such as deepest discharge, average discharge and the number of charge and discharge cycles.

All monitored battery parameters can be read out, and settings can be changed via the display and the four buttons.

A connection with the VictronConnect app is possible via Bluetooth or USB. The VictronConnect app can be used to read out all monitored battery parameters or to change settings. To connect via Bluetooth, an optional VE.Direct Bluetooth Smart dongle is needed. To connect via USB, an optional VE.Direct to USB interface is needed.

If the battery monitor is connected to a GX device, such as the Cerbo GX or the ColorControl GX, the battery can be monitored locally with the GX device or remotely via the VRM portal.

When connected to other Victron products via VE.Smart networking, the battery monitor can provide real-time battery data such as battery voltage and current via Bluetooth for use by Victron solar chargers and select AC chargers.

2.2. Why should I monitor my battery?

Batteries are used in a wide variety of applications, mostly to store energy for later use. But how much energy is stored in the battery? No one can tell by just looking at it. The service life of batteries depends on many factors. Battery life may be shortened by under-charging, over-charging, excessively deep discharges, excessive charge or discharge currents, and by high ambient temperature. Monitoring the battery with a battery monitor will give important feedback to the user so that remedial measures can be taken when necessary. Doing this will extend battery life and the battery monitor will quickly pay for itself.

2.3. Sizing

The battery monitor is available in one size; it has a 500A shunt. However, it is possible to use the battery monitor with larger shunts all the way up to 9999A. Larger shunts are not included. For 1000A, 2000A or 6000A shunts see the Shunt product page.

2.4. The VictronConnect app

The VictronConnect app can be used to monitor and configure the battery monitor. Note that configuring the battery monitor using the VictronConnect app is easier than configuring using the battery monitor head unit.

The VictronConnect app can connect to the battery monitor via:

- Bluetooth, using the optional VE.Direct Bluetooth Smart dongle.
- USB, using the optional VE.Direct to USB interface.
- · Remotely via a GX device and the VRM portal.

The VictronConnect app is available for the following platforms:

- Android.
- · Apple iOS (Note that USB is not supported, it is only possible to connect via Bluetooth).
- macOs.
- · Windows (Note that Bluetooth is not supported, it is only possible to connect via USB).

The VictronConnect app can be downloaded from app stores or from the VictronConnect product page or scan the below QR code.



2.5. Accessories

These optional parts might be needed depending on your setup:

- GX Device, such as a Cerbo GX for system and/or remote monitoring.
- VE.Direct cable to connect the battery monitor to a GX device.
- VE.Direct to USB interface to connect to the battery monitor via USB to a GX device or to the VictronConnect app.
- VE.Direct Bluetooth Smart dongle to add Bluetooth functionality to the battery monitor.
- Wall mount enclosure for BMV or MPPT Control use in case panel mounting of the battery monitor head unit is not possible.
- Wall mount enclosure for BMV and Color Control GX use to wall mount the battery monitor head unit together with a Color Control GX in the same enclosure.
- RJ12 UTP cable use in case the supplied 10m (32ft) RJ12 cable (the cable between the shunt and the head unit) is too long or too short. These cables are available in a variety of lengths of 30cm up to 30 meters (1ft up to 98ft).



3. Installation

3.1. What's in the box?

BMV-700 head unit together with attachment sleeve.	
500A shunt.	
1.5m (59") red cable with a 1A fuse.	
10m (33ft) RJ12 UTP cable.	
Square face plate together with an attachment flange.	
Bag with 4 small screws.	
Quick installation guide.	
Spare serial number sticker.	10000001284507760 1000000000000000000000000000000000


3.2. Mounting the shunt

The shunt has an IP21 rating; this means that the shunt is not waterproof and has to be mounted in a dry location.

The shunt has two 5.5 mm holes for mounting purposes; these are located in the base of the shunt. The holes can be used to screw or bolt the shunt onto a hard surface (note that these screws are not included).

For the exact location of the mounting holes see the dimension drawing [42] in the appendix of this manual.






Top view shunt indicating mounting holes and side view shunt indicating the mounting method.

3.3. Mounting the head unit


The head unit can be mounted in a variety of ways:

- A. Panel mounting, the head unit is secured at the back of a panel.
- B. Panel mounting, the head unit is secured at the front of the panel.
- C. Wall mounting, using an optional wall mounting enclosure.




Mounting method A.





Mounting method B.



For the full wall mounting instructions, see the wall mounting installation manuals on the Wall mount enclosure for BMV or MPPT Control or Wall mount enclosure for BMV and Color Control GX product pages.



A B C D E	G C C C C C C C C C C C C C C C C C C C	J F K	
-----------------------	--	-------	--

3.4. Connections overview

#	Name	Terminal type
A	Display	-
В	Setup button	-
С	Down button	-
D	Up button	-
E	Select button	-
F	RJ12 connector	RJ2 terminal
G	Buzzer	-
Н	Programmable relay connector	Push connector
I	VE.Direct connector	VE.Direct terminal
J	Negative battery connection	M10 bolt
К	Positive battery connection	Push connector
М	Negative load connection	M10 bolt

3.5. Basic electrical connections

Connection procedure:

1. Connect the negative battery terminal to the M10 bolt on the "BATTERY ONLY" side of the shunt. Tighten the shunt bolt with a maximum torque of 21Nm.


Note that there should be no other connections on this side of the shunt or on the negative battery terminal. Any loads or chargers connected here will be excluded from the battery state of charge calculation.

- Connect the negative of the electrical system to the M10 bolt on the "LOAD AND CHARGER" side of the shunt. Tighten the shunt bolt with a maximum torque of 21Nm. Make sure that the negative of all DC loads, inverters, battery chargers, solar chargers and other charge sources are connected "after" the shunt.
- 3. Connect the ferrule pin of the red cable with the fuse to the shunt by pushing the pin into to the "+B1" terminal.
- 4. Connect the M10 eye terminal of the red cable with the fuse to the positive terminal of the battery.
- 5. Connect the shunt to the head unit using the RJ12 cable. Plug one side of the RJ12 cable into the shunt RJ12 terminal and the other side of the cable into the RJ12 terminal on the rear of the head unit.

The battery monitor is now powered up. The display is active,.

In order to be fully functional, the battery monitor needs to be configured; see the Configuration [10] chapter.





Basic battery monitor installation.

3.6. Programmable relay


The battery monitor is equipped with a programable relay. This relay can be used as an alarm relay, to start a generator or for other applications. For more information on the various relay modes and how to configure the relay, see chapter Relay settings [26].

A usage example of the relay is to start a generator when the battery state of charge has dropped too low, and then to stop the generator when the batteries have been recharged.

By default, the relay is set to energise when the battery state of charge falls below 50% and to de-energise when the battery state of charge has risen to 90%. However, the relay can be configured to also trigger on other conditions, like battery voltage.

The relay has 2 contacts: COM (common) and NO (normally open) and are located on the back of the head unit.

When the relay contact is open, the coil is de-energised; there is no contact between COM and NO. When the relay is energised, the relay closes, and contact between COM and NO is made. The relay function can be inverted: de-energised becomes energised and vice versa. See setting Invert relay [27].



The internal wiring diagram of the battery monitor with the relay in a de-energised state connected to an external alarm or generator start circuit.

3.7. Use of alternative shunts

The battery monitor is supplied with a 500A, 50mV shunt. This shunt is suitable for most applications. However, a larger shunt will be required if system currents above 500A are expected.

The battery monitor can be configured to work with a wide range of different shunts. Shunts of up to 9999A and up to 75mV can be used. For a selection of larger shunts, i.e. 1000A, 2000A or 6000A, see our shunt product page.

When using a shunt other than the one supplied with the battery monitor, please proceed as follows:


- 1. Unscrew the circuit board from the shunt.
- 2. Mount the circuit board on the new shunt, and ensure that there is good electrical contact between the circuit board and the shunt.

- Connect the new shunt to the electrical system and battery monitor head unit as shown in chapter Basic electrical connections [7]. Pay special attention to the orientation of the shunt circuit board in relation to the battery and load connections.
- 4. Follow the setup wizard; see the Setup wizard [10] chapter.
- 5. After completing the setup wizard, set the proper shunt current and shunt voltage according to the Shunt current [32] and the Shunt voltage [32] settings.
- 6. If the battery monitor reads a non-zero current, even when there is no load, and the battery is not being charged, calibrate the zero current reading using the Zero current calibration [26] setting.

3.8. GX device connection

If the system contains a GX device such as a Cerbo GX, the battery monitor can be connected to the GX device using a VE.Direct cable or a VE.Direct to USB interface.

Once connected, the GX device can be used to read out all monitored battery parameters. For more information see chapter Connecting to a GX device and the VRM portal [21].



The battery monitor is connected to a Cerbo GX and a GX Touch screen.



4. Configuration

Once the electrical connections have been made, and the battery monitor has been powered up, it needs to be configured to be suitable for the system it is used in.

This can be done with the buttons on the battery monitor head unit or even easier via the VictronConnect app. Note that a VE.Direct Bluetooth Smart dongle or VE.Direct to USB interface is required.

This chapter describes how to configure the battery monitor by making the basic settings. See the All features and settings [23] chapter for all settings and features.

4.1. Setup wizard

The battery monitor will automatically start the setup wizard on the first power-up or after a factory reset. The setup wizard must be completed before any other settings are made.

- 1. The display shows the scrolling text "battery capacity": ballery CAPACIES
- 2. Press any button to enter the setup wizard. The scrolling text will stop, and the factory default battery capacity value 0200 Rh (200 Ah) will be shown with the first digit blinking.
- 3. Use the + and buttons to set the first digit of the battery capacity value. Preferably use the 20-hour (C20) battery capacity rating. For more information on battery capacity, see the Battery capacity and Peukert exponent [34] chapter.
- 4. Press SELECT to set the next digit in the same manner. Repeat this step until the required battery capacity is displayed.
- 5. Press SELECT to store the value. A short beep confirms this.

Should a correction need to be made, press SELECT again and repeat the previous steps.

6. Press the SETUP, + or – button to end the setup wizard and switch to the normal operating mode.

Immediately after the completion of the setup wizard, the battery monitor will automatically detect the nominal voltage of the battery system. For details and limitations of automatic voltage detection, see the next chapter Automatic voltage detection [10].

The battery monitor is now ready for use. It is now set up for an average system with GEL, AGM or flooded lead-acid batteries. Further battery monitor configurations are required if your system contains a battery with different chemistry, like lithium, or if other specific system settings are needed. See the All features and settings [23] chapter.



If the setup wizard is not showing, i.e. there is no scrolling text, it can be re-activated by performing a battery monitor reset. To do this: simultaneously press the SETUP and the SELECT button for 3 seconds. This resets the battery monitor to its factory settings.

Note that factory settings can only be restored if the Lock setup [31] setting has been set to OFF.

4.2. Automatic voltage detection

The battery monitor will automatically adjust itself to the nominal voltage of the battery bank. This happens immediately after the completion of the setup wizard. The below table shows how the nominal voltage is determined and to what nominal battery voltage the battery monitor is automatically set. See the Set charged voltage value [13] chapter for more information.

Measured voltage	Assumed nominal voltage
< 18V	12V
18 - 36V	24V
> 36V	48V



Note that the battery monitor is unable to detect a 32V nominal battery voltage. If the battery monitor is used with a 32V battery bank, the charged voltage must be set manually using the Charged voltage [24] setting.

4.3. How to change settings


4.3.1. Settings via the head unit

Use the display buttons to enter and navigate through the settings menu. Each setting has a number and a name. For example: "01 - Battery capacity". The full list of all battery settings and their corresponding number can be found in the All features and settings [23] chapter.





It is also possible (and easier) to make the battery monitor settings via the VictronConnect app. See the The VictronConnect app [11] chapter on how to do this.



BMV head unit display and buttons.

To access the settings menu and change settings:

1	Start in the main menu.	MAIN
2	Press SETUP for two seconds to enter the settings menu.	
3	The first setting item 01-Battery capacity will be shown.	SETUP
4	Use the + and – buttons to go to the desired setting item.	
5	Press SELECT to access the setting item.	
6	Use SELECT and the + and – buttons to customize the setting.	SETUP
7	Press SETUP to return to the setting menu.	
8	Go to the next setting using the + or - buttons.	
9	After all settings have been made, press SETUP to return from the settings menu to normal mode.	

4.3.2. The VictronConnect app

The VictronConnect app can be used to change all settings and to update the firmware.




Ways to connect to the battery monitor:

- · Locally via USB using the VE.Direct to USB interface connected to the VE.Direct port.
- · Locally via Bluetooth using the VE.Direct Bluetooth Smart dongle connected to the VE.Direct port.
- Remotely via a GX device, using VictronConnect "Remote" feature. For more information, see the VictronConnect-Remote chapter in the VictronConnect app manual.

How to connect with the VictronConnect app to the battery monitor:

- Open the VictronConnect app.
- · Ensure that the battery monitor is powered.
- · Look for the battery monitor to appear in the device list in the "Local" or the "VRM" tab.
- · Click on the battery monitor.
- In case of a connection via Bluetooth; enter the default PIN code: 000000. After entering the default PIN code, the VictronConnect app will ask you to change the PIN code. This is to prevent unauthorized connections in the future. It is recommended that you change the PIN code on the first installation.

To view and/or change battery monitor settings, navigate to the settings page by clicking on the cog icon 🌣 at the top right of the home screen.



The battery monitor monitoring and setting screens in the VictronConnect app.

Note that this manual only covers the items that are specific to the battery monitor. For more general information about the VictronConnect app, like how to use it and where to download it, or how to connect, see the VictronConnect app product page and manual.

4.4. Update firmware

On a new install, it is recommended to update the firmware of the battery monitor. If there is a newer firmware version available, the VictronConnect app will notify you of this as soon as a connection with the battery monitor is made.



E

Note that the firmware can only be updated via the VictronConnect app. The app needs to be up to date to be able to access the latest firmware.

To check if the firmware is up to date or to manually update firmware, connect to the battery monitor using the VictronConnect app and follow the below steps:

- Navigate to the product settings by clicking the "cog" 🌣 symbol in the top right-hand corner of the product status screen.
- Click on the "3 dots" symbol in the top right-hand corner of the settings screen.
- · Select "Product info" from the pop-up menu.
- The firmware version will be displayed. It is mentioned if this is the latest firmware version (or not). If a newer firmware version is available, an "UPDATE" button will be displayed.

• To update the firmware, press the "UPDATE" button.

4.5. Make essential settings

The default settings of the battery monitor are tailored for lead acid batteries, like AGM, GEL, OPzV or OPzS batteries.

Most settings can stay at their factory default. But there are a few settings that need to be changed. These are:

- Battery capacity.
- · Charged voltage.
- · State of charge or start synchronised.



If lithium batteries (or batteries with a different chemistry) are used, some additional settings will have to be changed.

First, make the essential settings as described in this paragraph and then refer to the next paragraph for the special lithium settings.



For more information about these and any of the other settings, see chapter All features and settings [23].

4.5.1. Set the battery capacity value

In the VictronConnect app, see: **Settings > Battery**.

Via the head unit, see: Setup menu > Setting 01 - Battery capacity.

The battery monitor is by default set to 200Ah. Change this value to match your battery capacity. For lead-acid batteries, we recommend entering the 20-hour (C20) rate.

4.5.2. Set charged voltage value

In the VictronConnect app, see: Settings > Battery > Charged voltage.

Via the head unit, see: Setup menu > Setting 02 - Charged voltage.

Although the battery monitor automatically detects the voltage, it is good practice to check if this setting is correctly set.

These are the recommended "Charged voltage" values for lead acid batteries:

Nominal battery voltage	Recommended charged voltage setting
12V	13.2V
24V	26.4V
36V	39.6V
48V	52.8V

For more information, also see the Charged voltage [24] chapter.

4.5.3. Set state of charge

In the VictronConnect app, see: Settings > Battery > Battery start synchronized.

Via the head unit, see: Setup menu > Setting 70 - Start synchronised.

When set to ON, the battery monitor will consider itself synchronized when powered up, resulting in a state of charge of 100%. If set to OFF, the battery monitor will consider itself un-synchronized when powered up, resulting in a state of charge that is unknown until the first actual synchronization.

<u>For VictronConnect only</u>: The initial state of charge value can also be manually set, by default, this is 100%, and can be set to a different value if so desired. See: **Settings > Battery > State-of-charge**.

4.6. Make Lithium settings (if needed)

LiFePO4 (Lithium Iron Phosphate or LFP) is the most used Li-ion battery chemistry. The factory defaults are in general also applicable to LFP batteries with exception of these settings:



- Tail current.
- · Peukert exponent.
- Charge efficiency.
- Discharge floor.

Tail current

In VictronConnect see: Settings > Battery > Tail current.

Via the head unit, see: Setup menu > Setting 03 - Tail current.

Some lithium battery chargers stop charging when the current drops below a set threshold. The tail current must be set higher in this case.

Peukert exponent

In VictronConnect see: Settings > Battery > Peukert exponent.

Via the head unit, see: Setup menu > Setting 05 - Peukert exponent.

When subjected to high discharge rates, lithium batteries perform much better than lead-acid batteries. Set the Peukert exponent at 1.05, unless the battery supplier advises otherwise.

Charge efficiency

In VictronConnect see: Settings > Battery > Charge efficiency factor.

Via the head unit, see: Setup menu > Setting 06 - Charge efficiency factor.

The charge efficiency of lithium batteries is much higher than that of lead-acid batteries. We recommend setting the charge efficiency at 99%.

Discharge floor

In VictronConnect see: Setting > Battery > Discharge floor

Via the head unit, see: Setup menu > Setting 16 - SoC relay.

This setting is used in "the time to go" calculation and is set at 50% by default for lead-acid batteries. However, lithium batteries usually can be discharged significantly deeper than 50%. The discharge floor can be set to a value between 10 and 20%, unless the battery supplier advises otherwise.



Important warning

Lithium batteries are expensive and can be irreparably damaged due to very deep discharge or overcharge. Damage due to deep discharge can occur if small loads slowly discharge the battery when the system is not in use. Some examples of these loads are alarm systems, standby currents of DC loads and back current drain of battery chargers or charge regulators.

A residual discharge current is especially dangerous if the system has been discharged all the way until a low cell voltage shutdown has occurred. At this moment the state of charge can be as low as 1%. The lithium battery will get damaged if any remaining current is drawn from the battery. This damage can be irreversible.

A residual current of 1mA for example can damage a 100Ah battery if the battery has been left in a discharged state for more than 40 days (1mA x 24h x 40 days = 0.96Ah).

The battery monitor draws <48mW from the battery. The positive supply must therefore be interrupted if a system with Li-ion batteries is left unattended during a period long enough for the battery monitor power consumption to completely discharge the battery.

In case of any doubt about the possible residual current draw, isolate the battery by opening the battery switch, by pulling the battery fuse(s) or by disconnecting the battery positive when the system is not in use.

5. Operation

5.1. How does the battery monitor work?

The main function of the battery monitor is to follow and indicate the state of charge of a battery, to be able to know how much charge the battery contains and to prevent an unexpected total discharge.

The battery monitor continuously measures the current flow in and out of the battery. Integration of this current over time, if it was a fixed current, boils down to multiplying current and time and gives the net amount of Ah added or removed.

For example, a discharge current of 10A for 2 hours will take 10 x 2 = 20Ah from the battery.

To complicate matters, the effective capacity of a battery depends on the rate of discharge, the Peukert efficiency, and, to a lesser extent, the temperature. And to make things even more complicated: when charging a battery more energy (Ah) has to be 'pumped' into the battery than can be retrieved during the next discharge. In other words: the charge efficiency is less than 100%. The battery monitor takes all these factors into consideration when calculating the state of charge.

5.2. Readout overview

The head unit display or the VictronConnect app battery monitor status screen, displays an overview of the most important parameters. These are:

- · State of charge
- · Battery voltage
- · Battery current
- Power

State of charge

This is the actual state of charge of the battery in a percentage and is compensated for both the Peukert efficiency and charge efficiency. The state of charge is the best way to monitor the battery.

A fully charged battery will be indicated by a value of 100.0%. A fully discharged battery will be indicated by a value of 0.0%.

Please note that if the state of charge indicates three dashes: "----" this means that the battery monitor is in an unsynchronised state. This mainly occurs when the battery monitor has just been installed or after the battery monitor has been left unpowered and is powered up again. For more information, see the Synchronising the battery monitor [19] chapter.

Voltage

This is the terminal voltage of the battery.

<u>Current</u>

This is the actual current flowing in or out of the battery. A negative current indicates that current is taken from the battery. This is the current needed for DC loads. A positive current means that current is going into the battery. This is current coming from charge sources. Keep in mind that the battery monitor will always indicate the total battery current, being the current traveling into the battery.

Power

The power drawn from or received by the battery.

Consumed Ah

The battery monitor keeps track of the Amp-hours removed from the battery compensated for the efficiency.

Example: If a current of 12A is drawn from a fully charged battery for a period of 3 hours, the readout will show -36.0Ah ($-12 \times 3 = -36$).

Please note that if the "Consumed Ah" reading indicates three dashes: "---" this means that the battery monitor is in an unsynchronised state. This mainly occurs when the battery monitor has just been installed or after the battery monitor has been left unpowered and is powered up again. For more information, see the Synchronising the battery monitor [19] chapter.

Time remaining

The battery monitor estimates how long the battery can support the present load. This is the "time-to-go" readout and is the actual time left until the battery is discharged to the set "discharge floor". The discharge floor is by default set at 50%. For the discharge floor setting see the Discharge floor [24] chapter. If the load is fluctuating heavily, it is best not to rely on this reading too much, as it is a momentary readout and should be used as a guideline only. We recommend the use of the state of charge readout for accurate battery monitoring.





If the "Time remaining" indicates three dashes: "---" this means that the battery monitor is in an unsynchronised state. This occurs when the battery monitor has just been installed or after it has been left unpowered and is powered up again. For more information, see see the Synchronising the battery monitor [19] chapter.

5.3. Using the head unit menus



Alternatively, use the VictronConnect app to access the battery monitor settings. See the chapter The VictronConnect app [11] on how to do this.

When the battery monitor is powered up for the first time or when the factory settings have been restored, the battery monitor will start the quick setup wizard; see chapter: Setup wizard [10]. After that, the battery monitor will operate in normal mode, and the battery menu can be accessed as described in this chapter.

The battery monitor is controlled by the four buttons on the head unit. The function of the buttons depends on which mode the battery monitor is in. This is indicated in the below table.

If the backlight is off, press any button to restore the backlight.

Button	Function when in normal mode	Function when in setup mode
SETUP	Press and hold for two seconds to switch to setup mode. The display will scroll the number and description of the selected parameter.	Press SETUP any time to return to the scrolling text, and press again to return to normal mode. When pressing SETUP while a parameter is out of range, the display blinks five times, and the nearest valid value is displayed.
SELECT	Press to switch to the history menu. Press to stop scrolling and show the value. Press again to switch back to normal mode.	 Press to stop scrolling after entering the setup mode with the SETUP button. After editing the last digit, press to end editing. The value is stored automatically. A short beep indicates confirmation. If required, press again to restart editing.
SETUP and SELECT simultaneously	Press and hold both SETUP and SELECT buttons simultaneously for three seconds to restore factory settings (disabled when setting 64, lock setup, is on, see Lock setup [31]).	n/a
	Maria	When not editing, press to move up to the previous parameter.
+	Move upwards.	When editing, this button will increment the value of the selected digit.
	Move downwards.	When not editing, press to move down to the next parameter.
-		When editing, this button will decrement the value of the selected digit.
+ and - simultaneously	Press and hold both buttons simultaneously for three seconds to manually synchronise the BMV.	n/a

5.4. Trends

The VictronConnect app provides battery monitor data logging, but only while the VictronConnect app is connected and communicating with the battery monitor. It will simultaneously log two of the following parameters:

- Voltage (V).
- Current (A).
- Power (W).
- Consumed Amp Hours (Ah).
- State of charge (%).



		TRENDS
Voltage (V)	✓ Current (A)	•
None		
Voltage (V)		-3.4 A
Current (A)		
Power (W)	10	1
Consumed Amp Hours (Ah)		IN I
State of Charge (%)	V · u	¥
Temperature (C)		
13.13 V		
13.11 V		-5.8 A
3.09 V	44	-6.6 A

VictronConnect app battery monitor trends.

5.5. History

The battery monitor stores historic events. These can be used at a later date to evaluate usage patterns and battery health.

The history data is stored in a non-volatile memory and will not be lost when the power supply to the battery monitor has been interrupted or when the battery monitor has been reset to its defaults.

5.5.1. Accessing historical data via the VictronConnect app

The battery monitor's historical data can be accessed in the "History" tab in the VictronConnect app.

STATUS	HISTORY	TRENDS
Deepest discharge -963Ah	Last dischi -359Ał	
Average discharge	Cumulative	
Discharged energy	Charged er 14608	
	Time since 1d 23h	
Min battery voltage	Max batter 32.07	

The VictronConnect app battery monitor history screen.

5.5.2. Accessing historical data via the head unit

To view the battery monitor history menu press SELECT when in normal mode:

- Press + or to browse the various parameters.
- Press + or to browse the various values.

- Press SELECT again to stop scrolling and show the value.
- Press SELECT again to leave the historical menu and to go back to the normal operation mode.

The below table gives an overview of the history parameters and how they are displayed in the menu. For the meaning of each parameter see the next chapter.

#	Display	Discription
А	A GEPESE di SCHA-9E	Deepest discharge
В	LASE di SCHA-9E	Last discharge
С		Average discharge
D		Cycles
E		Discharges
F		Cumulative Ah
G		Lowest voltage
Н		Highest voltage
I	; deus since lese cherse	Days since last discharge
J		Synchronisations
L		Low voltage alarms
М		High voltage alarms
R	r di Scharged Energy	Discharged energy
S	5 CHR-BEd Energy	Charged energy

5.5.3. History data

Discharge information in Ah

- **Deepest discharge:** The battery monitor remembers the deepest discharge and each time the battery is discharged deeper the old value will be overwritten.
- Last discharge: The battery monitor keeps track of the discharge during the current cycle and displays the largest value recorded for Ah consumed since the last synchronisation.
- Average discharge: The cumulative Ah drawn divided by the total number of cycles.
- Cumulative Ah drawn: The cumulative number of Amp hours drawn from the battery over the lifetime of the battery monitor.

Energy in kWh

- Discharged energy: This is the total amount of energy drawn from the battery in kWh.
- Charged energy: The total amount of energy absorbed by the battery in kWh.

<u>Charge</u>

- **Total charge cycles:** The number of charge cycles over the lifetime of the battery monitor. A charge cycle is counted every time the state of charge drops below 65% and then rises above 90%.
- Time since last full charge: The number of days since the last full charge.
- Synchronisations: The number of automatic synchronisations. A synchronisation is counted every time the state of charge drops below 90% before a synchronisation occurs.



• Number of full discharges: The number of full discharges. A full discharge is counted when the state of charge reaches 0%.

Battery voltage

- · Min battery voltage: The lowest battery voltage.
- · Max battery voltage: The highest battery voltage.

Voltage alarms

- · Low voltage alarms: The number of low voltage alarms.
- · High voltage alarms: The number of high voltage alarms.

5.6. Alarms

The battery monitor can raise an alarm in the following situations:

- Low battery state of charge (SOC).
- · Low battery voltage.
- · High battery voltage.

The alarm will activate when the value reaches a set threshold and will deactivate when the value clears this threshold. The thresholds are configurable. For more information, see the Alarm settings [28] chapter.

The alarm will be displayed on the head unit, a buzzer will sound, the display backlight will flash, and the alarm icon will be visible on the display. An alarm is acknowledged when a button is pressed. However, the alarm icon is displayed as long as the alarm condition remains. The programmable relay can be triggered depending on the configuration of the alarm settings.

The alarm is also a software alarm.

When connecting with the VictronConnect app, while an alarm is active, the alarm will show in the app. Alternatively, when the battery monitor is connected to a GX device, the alarm will show on the GX device display or the VRM portal.

In the case of the VictronConnect app, an alarm is acknowledged when a button is pressed. And in the case of a GX device, an alarm is acknowledged when viewed in notifications. The alarm icon is displayed as long as the alarm condition remains.

Time remaining	Infinite	<	Notifications	▲ 奈 16:51
Mid voltage	04:53 PM	Δ	SmartShunt 500A/50mV Alarm Mid-point voltage	2020-03-03 15:14 100.1%
Alerts	^		<u>ᆈ</u> Pages	≡ Menu

Left: alarm displayed on the VictronConnect app. Right: alarm displayed on a GX device.

5.7. Synchronising the battery monitor

For a reliable readout, the state of charge, as displayed by the battery monitor, must self-synchronise regularly with the true state of charge of the battery. This is to prevent drift of the "State of charge" value over time. A synchronisation will reset the state of charge of the battery to 100%.

5.7.1. Automatic synchronisation

Synchronisation is an automatic process and will occur when the battery has been fully charged. The battery monitor will look at a few parameters to ascertain that the battery has been fully charged. It will consider the battery to be fully charged when the voltage has reached a certain value and the current has dropped below a certain value for a certain amount of time.

These parameters are called:

- · Charged voltage the float voltage of the battery charger.
- · Tail current a percentage of the battery capacity.
- · Charged detection time the time in minutes.

As soon as these 3 parameters have been met, the battery monitor will set the state of charge value to 100%, thus synchronising the state of charge.

Example:

In the case of a 12V battery, the battery monitor will reset the battery's state of charge to 100% when all these parameters have been met:



- The voltage exceeds 13.2V,
- the charge current is less than 4.0% of the total battery capacity (e.g. 8A for a 200Ah battery) and,
- 3 minutes have passed while both the voltage and current conditions are met.

If the battery monitor does not perform a regular synchronisation, the state of charge value will start to drift over time. This is due to the small inaccuracies of the battery monitor and because of the estimation of the Peukert exponent [34]. Once a battery has been fully charged, and the charger has gone to the float stage, the battery is full and the battery monitor will automatically synchronise by setting the state of charge value to 100%.

5.7.2. Manual synchronisation

The battery monitor can be synchronised manually if required. This can be done by pressing the "Synchronise" button in the VictronConnect app. Navigate to "settings" and then to "battery settings".

Alternatively, the battery monitor can be synchronised when in normal operating mode by simultaneously pressing and holding the + and – buttons for 3 seconds.

A manual synchronisation can be needed in situations when the battery monitor does not synchronise automatically. This is for example needed during the first installation or after the voltage supply to the battery monitor has been interrupted.

A manual synchronisation can also be needed when the battery has not been fully charged, or if the battery monitor has not detected that the battery has been fully charged because the charged voltage, current or time has been set incorrectly. In this case, review the settings and make sure the battery regularly receives a full charge.



6. Interfacing


The battery monitor can be connected to other equipment, this chapter describes how this can be done.

6.1. VictronConnect app via USB

The VictronConnect app can not only connect via Bluetooth but it can also connect via USB. A USB connection is essential when connecting to the Windows version of the VictronConnect app and is optional when the MacOS or Android version is used. Please note that in case of connecting to an Android phone or tablet a "USB on the Go" cable might be needed.

To connect via USB, you will need a VE.Direct to USB interface. Use this interface to connect the computer to the battery monitor. for more information see the VE.Direct to USB interface product page.

For more information also see the VictronConnect app manual.



Example of a VE.Direct to USB interface connection between the battery monitor and a computer.

#	Description
A	VE.Direct to USB interface.
В	Computer or laptop.

6.2. Connecting to a GX device and the VRM portal


A GX device, such as the Cerbo GX, is a Victron Energy device that provides control and monitoring for all Victron equipment that is connected to it. Control and monitoring of the GX device and it's connected equipment can be done locally or remotely via our free Victron Remote Monitoring portal, the VRM portal.

The battery monitor can be connected to a GX device with a VE.Direct cable. The VE.Direct cables are available in lengths ranging from 0.3 to 10 meters and are available with straight or right-angle connectors. Alternatively, the battery monitor can also connect to a GX device using a VE.Direct to USB interface.

Once connected, the GX device can be used to read out all monitored battery parameters.

<	BMV-700		15:06
Battery	26.15V	-5.7A	-149W
State of charge			100%
Consumed AmpHours 0.0Ah			
Time-to-go			10d 0h
Relay state			On
Alarm state			Ok
패 Pages 🗸 🖃 Menu			enu

Battery monitor information displayed by a GX device.



Example of a battery monitor connecting to a GX device.

6.3. Connecting to VE.Smart networking



Note that the BMV-700 can only transmit battery voltage and battery current to VE.Smart networking. It can not transmit battery temperature. If the battery temperature is needed use a BMV 700, BMV-712, SmartShunt or SmartShunt IP65 instead. For more information see our battery monitor product page.

VE.Smart networking is a wireless network that allows a number of Victron products to exchange information via Bluetooth. The battery monitor can share the following information with the network:

- · Battery voltage.
- · Battery current.

To make the battery monitor part of VE.Smart networking, you will have to either create a network or join an existing network. The setting can be found in the VictronConnect app. Navigate to the battery monitor page and then to: settings > smart networking. Please see the VE.Smart networking manual for more information.



Creating a VE.Smart network using the VictronConnect app.

6.4. Custom integration

Please note that this is an advanced feature and requires programming knowledge.

The VE.Direct communications port can be used to read data and change settings. The VE.Direct protocol is extremely simple to implement. Transmitting data to the battery monitor is not necessary for simple applications: the battery monitor automatically sends all readings every second.

All the details are explained in the Data communication with Victron Energy products document.



7. All features and settings

This chapter explains all battery monitor settings. In addition to this we also have a video available explaining these settings and how the interact with each other to achieve accurate battery monitoring for both lead acid and lithium batteries.

Link to the video:

https://www.youtube.com/embed/mEN15Z_S4kE

7.1. How to change settings

Settings can be changed by using the battery monitor's head unit or by using the VictronConnect app.

7.1.1. Accessing settings via the head unit

To access and change setting parameters use the buttons on the head unit in the following way:

- Press SETUP for two seconds to access these functions and use the+ and buttons to browse them.
- · Press SELECT to access the desired parameter.
- · Use SELECT and the + and buttons to customize. A short beep confirms the setting.
- Press SETUP at any time to return to the scrolling text, and press again to return to normal mode.

7.1.2. Accessing settings via the VictronConnect app

To access and change setting parameters do the following:

- Click on the settings symbol ^C to go to the battery settings menu.
- To navigate from the general settings menu to the product settings menu, click on the menu symbol .

For information on how to connect with the VictronConnect app to the battery monitor, see the The VictronConnect app [11] chapter.

7.1.3. Saving, loading and sharing settings in VictronConnect

In the settings menu you can find the following 3 symbols:

Save settings to file - This will save settings for reference or for later use.

Load settings from file - This will load earlier saved settings.

Share settings file – This allows you to share the settings file via email, message, airdrop and so on. The available sharing options depend on the platform used.

For more information on these features, see the VictronConnect manual.

7.2. Battery settings

The battery settings can be used to fine-tune the battery monitor. Please be careful when you change these settings, as a change might affect the battery monitor's state of charge calculations.

7.2.1. Battery capacity

This parameter is used to tell the battery monitor how big the battery is. This setting should already have been done during the initial installation.

The setting is the battery capacity in Amp-hours (Ah).

For more information on the battery capacity and the related Peukert exponent see the Battery capacity and Peukert exponent [34] chapter.

Se	tting	Default	Range	Step size
Battery capac	city (setting 01)	200Ah	1 - 9999Ah	1Ah

7.2.2. Charged voltage

The battery voltage must be above this voltage level to consider the battery as fully charged. As soon as the battery monitor detects that the voltage of the battery has reached this "charged voltage" parameter and the current has dropped below the "tail current [24]" parameter for a certain amount of time, the battery monitor will set the state of charge to 100%.

Setting	Default	Range	Step size
	13.2V (12V nominal)		
Charged voltage (setting 02)	26.4V (24V nominal)	0 - 95V	0.1V
	52.8V (48V nominal)		

The "charged voltage" parameter should be set to 0.2V or 0.3V below the float voltage of the charger.

The table below indicates the recommended settings for lead acid batteries.

Nominal battery voltage	Charged voltage setting
12V	13.2V
24V	26.4V
36V	39.6V
48V	52.8V
60V	66V

7.2.3. Discharge floor

The "Discharge floor" parameter is used in the "time remaining" calculation. The battery monitor calculates the time it takes until the set "discharge floor [24]" has been reached. It is also used to set the state of charge alarm defaults.

For lead-acid batteries set this to 50% and for lithium set it lower.

Note that this setting only appears when accessing the battery monitor via the VictronConnect app. In case the battery monitor is accessed via the head unit, see the Low State of Charge (SoC) relay [27] setting instead.

Setting	Default setting	Range	Step size
Discharge floor	50%	0 - 99%	1%

7.2.4. Tail current

The battery is considered as fully charged once the charge current has dropped to less than this "Tail current" parameter. The "Tail current" parameter is expressed as a percentage of the battery capacity.

Note that some battery chargers stop charging when the current drops below a set threshold. In these cases, the tail current must be set higher than this threshold.

As soon as the battery monitor detects that the voltage of the battery has reached the set "Charged voltage [24]" parameter and the current has dropped below this "Tail current" parameter for a certain amount of time, the battery monitor will set the state of charge to 100%.

Setting	Default	Range	Step size
Tail current (setting 03)	4.00%	0.50 - 10.00%	0.1%

7.2.5. Charged detection time

This is the time the "Charged voltage [24]" parameter and the "Tail current [24]" parameter must be met in order to consider the battery fully charged.

Setting	Default setting	Range	Step size
Charged detection time (setting 04)	3 minutes	0 - 100 minutes	1 minute

7.2.6. Peukert exponent

Set the Peukert exponent parameter according to the battery specification sheet. If the Peukert exponent is unknown, set it at 1.25 for lead-acid batteries and set it at 1.05 for lithium batteries. A value of 1.00 disables the Peukert compensation. The Peukert value for lead-acid batteries can be calculated. For more information on the Peukert calculation, the Peukert exponent and how this relates to the battery capacity, see the Battery capacity and Peukert exponent [34] chapter.



Setting	Default	Range	Step size
Peukert exponent (setting 05)	1.25	1.00 - 1.50	0.01

7.2.7. Charge efficiency factor

The "Charge Efficiency Factor" compensates for the capacity (Ah) losses during charging. A setting of 100% means that there are no losses.

A charge efficiency of 95% means that 10Ah must be transferred to the battery to get 9.5Ah actually stored in the battery. The charge efficiency of a battery depends on battery type, age and usage. The battery monitor takes this phenomenon into account with the charge efficiency factor.

The charge efficiency of a lead acid battery is almost 100% as long as no gas generation takes place. Gassing means that part of the charge current is not transformed into chemical energy, which is stored in the plates of the battery, but is used to decompose water into oxygen and hydrogen gas (highly explosive!). The energy stored in the plates can be retrieved during the next discharge, whereas the energy used to decompose water is lost. Gassing can easily be observed in flooded batteries. Please note that the 'oxygen only' end of the charge phase of sealed (VRLA) gel and AGM batteries also results in a reduced charge efficiency.

Setting	Default setting	Range	Step size
Charge efficiency factor (setting 06)	95%	50 - 100%	1%

7.2.8. Current threshold

When the current measured falls below the "Current threshold" parameter it will be considered zero. The "Current threshold" is used to cancel out very small currents that can negatively affect the long-term state of charge readout in noisy environments. For example, if the actual long-term current is 0.0A and, due to injected noise or small offsets, the battery monitor measures 0.05A the battery monitor might, in the long term, incorrectly indicate that the battery is empty or will need to be recharged. When the current threshold in this example is set to 0.1A, the battery monitor calculates with 0.0A so that errors are eliminated.

A value of 0.0A disables this function.

Setting	Default	Range	Step size
Current threshold (setting 07)	0.10A	0.00 - 2.00A	0.01A

7.2.9. Time-to-go averaging period

The time-to-go averaging period specifies the time window (in minutes) that the moving averaging filter works. A value of 0 (zero) disables the filter and gives an instantaneous (real-time) readout. However, the displayed "Time remaining" value may fluctuate heavily. Selecting the longest time, 12 minutes, will ensure that only long-term load fluctuations are included in the "Time remaining" calculations.

Setting	Default	Range	Step size
Time-to-go averaging period (setting 08)	3 minutes	0 - 12 minutes	1 minute

7.2.10. Battery starts synchronised

Note that if the battery monitor settings are accessed via the head unit, this setting will be part of the miscellaneous setting, and if accessed via VictronConnect it will be part of the battery settings.

The battery state of charge will become 100% after the battery monitor is powered up. When set to ON, the battery monitor will consider itself synchronised when powered up, resulting in a state of charge of 100%. If set to OFF, the battery monitor will consider it unsynchronised when powered up, resulting in a state of charge that is unknown until the first actual synchronisation.

Please be aware that situations can occur where special consideration is needed when setting this feature to ON. One of these situations occurs in systems where the battery is often disconnected from the battery monitor, for example on a boat. If you leave the boat and disconnect the DC system via the main DC breaker and at that moment the batteries were, for example, 75% charged. On return to the boat, the DC system is reconnected and the battery monitor will now indicate 100%. This will give a false impression that the batteries are full, while in reality they are partially discharged.

There are two ways of solving this, one is to not disconnect the battery monitor when the batteries are partially discharged or alternatively turn the "Battery starts synchronised" feature off. Now when the battery monitor is reconnected the state of charge will display "---" and will not show 100% until the batteries have been fully charged. Please note that leaving a lead acid battery in a partially discharged state for a length of time will cause battery damage.

Setting	Default	Modes
Start synchronized (setting 70)	ON	ON/OFF

7.2.11. State of charge

With this setting, you can manually set the state of charge value. This setting is only active after the battery monitor has, at least once, been synchronised. Either automatically or manually.

This setting is only available when accessing the battery monitor via the VictronConnect app.

Setting	Default	Range	Step size
State of charge	%	0.0 - 100%	0.1%

7.2.12. Synchronise SoC to 100%

Setting 10

This option can be used to manually synchronise the battery monitor.

When navigating to this setting on the head unit , press the SELECT button to synchronize the battery monitor to 100%.

In the VictronConnect app press the "Synchronise" button to synchronise the battery monitor to 100%.

See the Manual synchronisation [20] paragraph for more information on this setting.


7.2.13. Zero current calibration

Setting 09

This option can be used to calibrate the zero reading if the battery monitor reads a non-zero current even when there is no load and the battery is not being charged.

A zero current calibration is (almost) never needed. Only perform this procedure in case the battery monitor shows a current while you are absolutely sure that there is no actual current flowing. The only way to be sure is to physically disconnect all wires and cables connected to the LOAD AND CHARGER side of the shunt. Do this by unscrewing the shunt bolt and removing all cables and wires from that side of the shunt. The alternative, switching loads or chargers off, is NOT accurate enough as this does not eliminate small standby currents.

Ensure that there really is no current flowing into or out of the battery (disconnect the cable between the load and the shunt), then press SELECT in the head unit menu or press CALIBRATE in the VictronConnect app.



Performing a zero current calibration.

7.3. Relay settings

The battery monitor is equipped with a programmable relay. These settings are used to program the function of the relay.

The relay settings are disabled by default (except the State of Charge (SoC) relay setting). To enable, a relay setting do the following:

- In the VictronConnect app, enable the relay setting by sliding the slider button to the right.
- · Via the head unit, enable the relay setting by changing the set and clear value to any value above zero.

7.3.1. Relay mode

This setting has the following relay modes, namely:

Setting	Default mode	Modes	Description
		DFLT Default mode.	The relay settings 16 up to 31 can be used to control the relay.
Relay mode (setting 11)	DFLT	CHRG Charger mode.	The relay will close when the state of charge falls below setting 16 (discharge floor) or when the battery voltage falls below setting 18 (low voltage relay). The relay will be open when the state of charge is higher than setting 17 (clear state of charge relay) and the battery voltage is higher than setting 19 (clear low voltage relay). An application example is to start and stop control of a generator, together with settings 14 and 15.
		REM Remote mode.	The relay can be controlled via the VE.Direct interface. Relay settings 12 and 14 up to 31 are ignored as the relay is under the full control of the device connected via the VE.Direct interface.

7.3.2. Invert relay

This function enables selection between a normally de-energised (contact open) or a normally energised (contact closed) relay.

When inverted, the open and closed conditions as described in all the relay settings are inverted (with the exception of the Relay state [27]).

Note that the "normally energised" setting will slightly increase the power consumption of the battery monitor.

Setting	Default mode	Modes	Range
Invert relay (potting 12)	OFF	OFF	Normally de-energised
Invert relay (setting 12)	ULL	ON	Normally energised

7.3.3. Relay state

This is a read-only parameter and it displays whether the relay is open or closed (de-energised or energised).

Setting	Value	Description
	OPEN	The relay is open (de-energised)
Relay state (setting 13)	CLSD	The relay is closed (energised)

7.3.4. Relay minimum closed time

Sets the minimum time the "closed" condition will remain present after the relay has been energised.

Note that this changes to "open" and de-energised if the relay function has been inverted (Invert relay [27] setting).

An application example is to set a minimum generator run time when the relay is set to "charger" mode (Relay mode [26] setting).

Setting	Default	Range	Step size
Relay minimum closed time (setting 14)	0 minutes	0 - 8 hours	1 minute

7.3.5. Relay off delay

Sets the amount of time the "de-energise relay" condition must be present before the relay opens.

An application example is to keep a generator running for a while to charge the battery better when the relay is set to "charger" mode (Relay mode [26] setting).

Setting	Default	Range	Step size
Relay off delay (setting 15)	0 minutes	0 - 500 minutes	1 minute

7.3.6. Low State of Charge (SoC) relay

When the state of charge percentage has fallen below the "set relay" value, the relay will close.

When the state of charge percentage has risen above the "clear relay" value, the relay will open (after a delay, depending on the Relay minimum closed time [27] and/or the Relay off delay [27] settings).

The "clear relay" value needs to be greater than the "set relay" value.

Setting	Default	Range	Step size
Set relay value (setting 16)	50%	0 - 99%	1%
Clear relay value (setting 17)	90%	0 - 99%	1%



When the "set relay" and "clear relay" values are equal, the state of charge condition will be unable to drive the relay.



Note that this setting is also known as the discharge floor. The time-to-go reading displayed by the battery monitor relates to this setting. The time to go is the time left until this setting (the discharge floor) has been reached.

7.3.7. Low voltage relay

When the battery voltage falls below the "set relay" value for more than 10 seconds the relay will close.

When the battery voltage rises above the "clear relay" value, the relay will open (after a delay, depending on the Relay minimum closed time [27] and/or the Relay off delay [27] settings).

The "clear relay" value needs to be greater than the "set relay" value.

Setting	Default	Range	Step size
Set relay value (setting 18)	0V	0 - 95V	0.1V
Clear relay value (setting 19)	0V	0 - 95V	0.1V

7.3.8. High voltage relay

When the battery voltage rises above the "set relay" value for more than 10 seconds the relay will close.

When the battery voltage falls below the "clear relay" value, the relay will open (after a delay, depending on the Relay minimum closed time [27] and/or the Relay off delay [27] settings).

The "clear relay" value needs to be greater than the "set relay" value.

Setting	Default	Range	Step size
Set relay value (setting 20)	0V	0 - 95V	0.1V
Clear relay value (setting 21)	0V	0 - 95V	0.1V

7.4. Alarm settings

The BMV battery monitor is equipped with an alarm relay and a buzzer. Alarms are also visible on the VictronConnect app while connected to the battery monitor or are used to send an alarm signal to a GX device.

Alarms are disabled by default. To enable do the following:

- In the VictronConnect app, enable the alarm by sliding the slider button to the right.
- Via the head unit, enable the alarm by changing the "set" and "clear" value in the alarm settings to any value above zero.

7.4.1. Alarm buzzer

When enabled (set to ON), the buzzer will sound an alarm as soon as an alarm condition occurs. After a button is pressed, the buzzer will stop sounding.


When disabled (set to OFF) the buzzer will not sound an alarm.

Setting	Default	Modes
	Alarm buzzer (setting 32) ON	ON
Alarm buzzer (setting 32)		OFF

7.4.2. Low SoC alarm settings

When enabled, the alarm will activate when the state of charge (SoC) falls below the set value for more than 10 seconds. The alarm will deactivate when the state of charge rises above the clear value

Setting	Default	Range	Steps
Set alarm value (setting 33)	1%	0 - 100%	1%
Clear alarm value (setting 34)	1%	0 - 100%	1%



7.4.3. Low voltage alarm

When enabled, the alarm will activate when the battery voltage falls below the set value for more than 10 seconds. The alarm will deactivate when the battery voltage rises above the clear value.

Setting	Default	Range	Steps
Set alarm value (setting 35)	1.1V	0 - 95.0V	0.1V
Clear alarm value (setting 36)	1.0V	0 - 95.0V	0.1V

7.4.4. High voltage alarm

When enabled, the alarm will activate when the battery voltage rises above the set value for more than 10 seconds. The alarm will deactivate when the battery voltage drops below the clear value.

Setting	Default	Range	Steps
Set alarm value (setting 37)	1.1V	0 - 95.0V	0.1V
Clear alarm value (setting 38)	1.0V	0 - 95.0V	0.1V

7.5. Display settings

7.5.1. Backlight intensity

The intensity of the backlight This setting ranges from 0 (always off) to 9 (maximum intensity).

Setting	Default	Range	Step size
Backlight intensity (setting 49)	5	0 - 9	1

7.5.2. Backlight always on

When set the backlight will not automatically turn off after 60 seconds of inactivity.

Setting	Default	Modes
	OFF	ON
Backlight always on (setting 50)		OFF



7.5.3. Scroll speed

The scroll speed of the display. This setting ranges from 1 (very slow) to 5 (very fast).

Setting	Default	Range	Step size
Scroll speed (setting 51)	2	1 - 5	1

7.5.4. Main voltage display

Must be set to ON to display the voltage of the main battery in the monitoring menu.

Setting	Default	Modes
Main voltage diaplay (acting 52)	ON	ON
Main voltage display (setting 52)		OFF

7.5.5. Current display

Must be set to ON to display the current in the monitoring menu.

Setting	Default	Modes
Current diaplay (actting 52)	ON	ON
Current display (setting 53)	ON	OFF

7.5.6. Power display

Must be set to ON to display the power measurement in the monitoring menu.

Setting	Default	Modes
Power display (actting 54)		ON
Power display (setting 54)	ON	OFF

7.5.7. Consumed Ah display

Must be set to ON to display the consumed Ah in the monitoring menu.

Setting	Default	Modes
Concurred Ab display (actting EE)	ON	ON
Consumed Ah display (setting 55)		OFF

7.5.8. State of charge display

Must be set to ON to display the battery state of charge in the monitoring menu.

Setting	Default	Range	Step size
State of charge display (setting 56)	5	1 - 5	1

7.5.9. Time-to-go display

Must be set to ON to display the state of charge in the monitoring menu.

Setting	Default	Modes
Time to go display (setting E7)	Time to an display (acting 57)	ON
Time-to-go display (setting 57)	ON	OFF



7.6. Miscellaneous settings

7.6.1. Software version

Setting 61

This is a read-only setting. it displays the firmware version of the battery monitor.

The software version as displayed on the head unit is the same as the firmware version as displayed in the VictronConnect app product settings. In addition to this, the VictronConnect app also allows updating of the firmware. For more information see the Firmware [32] setting.

Setting	Default	Mode
Software version (setting 61)	Displays the battery monitor firmware version.	Read-only

7.6.2. Restore defaults

Setting 62

This head unit setting resets all settings to factory default.

The defaults can also be restored via the VictronConnect app. For more information on how to do this see the Reset to defaults [33] chapter.

To restore defaults do the following:

- Navigate to setting 62: the text "restore defaults" is displayed
- · Press SELECT on the head unit: the blinking text "reset" is displayed.
- Press SELECT again: a beep is heard, and all settings have gone back to factory default.
- Should the reset function have been entered accidentally and the text "reset" is blinking, press SETUP to leave and go back to the regular settings menu.

Note that restoring the defaults does not clear the history settings. To clear the history see the Clear history [31] setting.

When in normal operating mode, the factory settings can also be restored by pressing SETUP and SELECT simultaneously for 3 seconds on the head unit. Note that this is only possible if the Lock setup [31] setting is off.

7.6.3. Clear history

Setting 63

This setting resets all settings to factory default. To clear the history do the following:

- · Navigate to setting 63: the text "clear history" is displayed
- Press SELECT on the head unit: the blinking text "clear" is displayed.
- · Press SELECT again: a beep is heard and all settings have gone back to factory default.
- Should the reset function have been entered accidentally and the text "clear" is blinking, press SETUP to leave and go back to the regular settings menu.

The history can also be cleared via the VictronConnect app, for more information on how to do this see the Reset history [32] chapter.



Please be aware that history data is an important tool to keep track of battery performance and is also needed to diagnose possible battery problems. Do not clear the history unless the battery bank is replaced.

7.6.4. Lock setup

When on, all settings (except this one) are locked (read-only) and cannot be altered via the head unit. Note that they still can be altered via the VictronConnect app.

Setting	Default	Modes
Lock setup (setting 64)	OFF	ON/OFF

7.6.5. Shunt current

When a shunt other than the one supplied with the battery monitor is used, use this setting to set the rated current of the shunt.

Setting	Default	Range	Step size
Shunt current (setting 65)	500A	1 - 9999A	1A

7.6.6. Shunt voltage

When a shunt other than the one supplied with the battery monitor is used, use this setting to change the rated voltage of the shunt.

Setting	Default	Range	Step size
Shunt voltage (setting 66)	50mV	1 - 75mV	1mV

7.6.7. Battery starts synchronised

Note that if the battery monitor settings are accessed via the head unit, this setting will be part of the miscellaneous setting, and if accessed via VictronConnect it will be part of the battery settings.

For full information about this setting see the Battery starts synchronised [25] chapter.

Setting	Default	Modes
Start synchronized (setting 70)	ON	ON/OFF

7.7. Additional settings

These VictronConnect settings are not located in the VictronConnect settings menu but are located elsewhere in the VictronConnect app.

7.7.1. Reset history

/!\

This setting can be found at the bottom of the history tab.

This setting can also be made via the head unit. For more information see the Clear history [31]chapter.

Please be aware that history data is an important tool to keep track of battery performance and is also needed to diagnose possible battery problems. Do not clear the history unless the battery bank is replaced.

7.7.2. Reset PIN code

Note that the PIN code is only applicable when connecting to the battery monitor via Bluetooth.

This setting can be found in the settings of the VictronConnect app itself. Leave the battery monitor by clicking on the \leftarrow arrow. This will bring you back to the device list of the VictronConnect app. Now, click on the menu symbol next to the battery monitor listing.

A new window will open which allows you to reset the PIN code back to its default: 000000. To be able to reset the PIN code you will need the enter the battery monitor unique PUK code. The PUK code is printed on the product information sticker on the Battery monitor.

7.7.3. Serial number

The serial number can be found in the battery monitor product info section of the VictronConnect app or on the product information sticker rear of the battery monitor head unit.

7.7.4. Custom name

In the battery monitor product information screen, you can change the name of the battery monitor. By default, it is called by its product name. But a more applicable name might be needed, especially if you are using multiple battery monitors in close proximity of each other it might become confusing with which battery monitor you are communicating. You can, for example, add identification numbers to their name, like: Battery Monitor A, Battery Monitor B and so on.

7.7.5. Firmware

The battery monitor runs on firmware.



Occasionally a newer firmware version is available. New firmware is released to either add features or to fix a bug. The product overview in the VictronConnect app displays the battery monitor firmware version. It also indicates whether the firmware is the latest version, and there is a button you can press to update the firmware.

On the first installation, it is always recommended to update to the most recent firmware (if available). Whenever you connect to the battery monitor with an up-to-date version of the VictronConnect app, it will check the firmware, and if there is a newer version available, it will ask you to update the firmware. The VictronConnect app contains the actual firmware files, so an internet connection is not needed to update to the most recent firmware as long as you are using the most up-to-date version of the VictronConnect app.

A firmware update is not mandatory. If you choose not to update the firmware, you can only read out the battery monitor, but you cannot change settings. Settings can only be changed if the battery monitor runs on the most recent firmware.

For more information on firmware updates also see the VictronConnect app manual Firmware update chapter.

This setting is also available via the head unit Software version [31] setting. But note that this is a read-only setting. The firmware cannot be updated via the head unit.

7.7.6. Reset to defaults

To set all settings back to default select "Reset to defaults". Please note that this only resets all settings to their default values, the history is not reset.

This setting is also available via the head unit. For more information see the Restore defaults [31] chapter.



8. Battery capacity and Peukert exponent

Battery capacity is expressed in Amp hour (Ah) and indicates how much current a battery can supply over time. For example, if a 100Ah battery is being discharged with a constant current of 5A, the battery will be totally discharged in 20 hours.

The rate at which a battery is being discharged is expressed as the C rating. The C rating indicates how many hours a battery with a given capacity will last. 1C is the 1h rate and means that the discharge current will discharge the entire battery in 1 hour. For a battery with a capacity of 100Ah, this equates to a discharge current of 100A. A 5C rate for this battery would be 500A for 12 minutes (1/5 hours), and a C5 rate would be 20A for 5 hours.

There are two ways of expressing the C rating of a battery. Either with a number before the C or with a number after the C.

For example:

- 5C is the same as C0.2
- 1C is the same as C1
- 0.2C is the same as C5

The capacity of a battery depends on the rate of discharge. The faster the rate of discharge, the less capacity will be available. The relation between slow or fast discharge can be calculated by Peukert's law and is expressed by the Peukert exponent. Some battery chemistries suffer more from this phenomenon than others. Lead acid are more affected by this than lithium batteries are. The battery monitor takes this phenomenon into account with Peukert exponent.

Discharge rate example

A lead acid battery is rated at 100Ah at C20, this means that this battery can deliver a total current of 100A over 20 hours at a rate of 5A per hour. C20 = 100Ah (5 x 20 = 100).

When the same 100Ah battery is discharged completely in two hours, its capacity is greatly reduced. Because of the higher rate of discharge, it may only give C2 = 56Ah.

Peukert's formula

The value which can be adjusted in Peukert's formula is the exponent n: see the formula below.

In the battery monitor the Peukert exponent can be adjusted from 1.00 to 1.50. The higher the Peukert exponent the faster the effective capacity 'shrinks' with increasing discharge rate. An ideal (theoretical) battery has a Peukert exponent of 1.00 and has a fixed capacity regardless of the size of the discharge current. The default setting in the battery monitor for the Peukert exponent is 1.25. This is an acceptable average value for most lead acid batteries.

Peukert's equation is stated below:

 $Cp = I^n x t$ Where Peukert's exponent n is:

$$n = \frac{\log t2 - \log t1}{\log I1 - \log I2}$$

To calculate the Peukert exponent you will need two rated battery capacities. This is usually the 20h discharge rate and the 5h rate, but can also be the 10h and 5h, or the 20h and the 10h rate. Ideally use a low discharge rating together with a substantially higher rating. Battery capacity ratings can be found in the battery datasheet. If in doubt contact your battery supplier.



Calculation example using the 5h and the 20h rating

The C5 rating is 75Ah. The t1 rating is 5h and 11 is calculated:

$$I_1 = \frac{75Ah}{5h} = 15A$$

The C20 rating is 100Ah. The t2 rating is 20h and I2 is calculated:

$$I_2 = \frac{100Ah}{20h} = 5A$$

The Peukert exponent is:

$$n = \frac{\log 20 - \log 5}{\log 15 - \log 5} = 1.26$$

A Peukert calculator is available at http://www.victronenergy.com/ support-and-downloads/software#peukert-calculator.

Calcula With 'C-ratin	ite Peukert's Exp	onent	<u>_ </u>
Type the battery capacity for the 20hr discharge rate :			e rate :
t1 :	5 hrs	C5 rating :	75 Ah
t2 :	20 hrs	C20 rating :	100 Ah
			Calculate
Equation :	Equation :		
Peukert's exponent n = $\frac{\log 20 \cdot \log 5}{\log 15 \cdot \log 5}$ = 1.26			
Calculation	results :		
C20 rating	g :		Ah
Peukert's	exponent :		1.26
			<u>C</u> lose

Please note that the Peukert exponent is no more than a rough approximation of reality. In case of very high currents, the battery will give even less capacity than predicted by a fixed exponent. We do not recommend changing the default value in the battery monitor, except in the case of lithium batteries.



9. Troubleshooting

9.1. Functionality issues

9.1.1. Unit is dead

On first connection the display of the head unit should be active.

If this is not the case check the fuse in the +B1 cable and also check the cable itself and its terminals.

9.1.2. Unable to change VictronConnect settings

Settings can only be changed if the battery monitor is running on the most up to date firmware. Update to the latest firmware with the VictronConnect app.

9.2. Connection issues

9.2.1. Cannot connect via Bluetooth

It is highly unlikely that the Bluetooth interface is faulty. Some pointers to try before seeking support:

- Is the battery monitor connected to a VE.Direct Bluetooth Smart dongle? The battery monitor does not have built-in Bluetooth.
 The VE.Direct Bluetooth Smart dongle needs to be connected to the VE.Direct terminal of the head unit to equip the battery monitor with Bluetooth.
- Is the battery monitor powered up? The display on the head unit should be active. If not see the Unit is dead [36] chapter.
- Is another phone or tablet already connected to the battery monitor? Only one phone or tablet can be connected to the battery monitor at any given time. Make sure no other devices are connected and try again.
- · Is the VictronConnect app up to date?
- · Are you close enough to the battery monitor? In an open space, the maximum distance is about 20 meters.
- Are you using the Windows version of the VictronConnect app? This version is unable to connect via Bluetooth. Use Android, iOS or macOS instead (or use the USB VE.Direct interface).
- Has Bluetooth been turned off in the settings? See the ??? chapter.

For connection issues, see the troubleshooting section of the VictronConnect manual: https://www.victronenergy.com/live/victronconnect:start.

9.2.2. PIN code lost

Note that the PIN code is only applicable when connecting to the battery monitor via Bluetooth.

If you have lost the PIN code you will need to reset the PIN code to its default PIN code, see the Reset PIN code [32] chapter.

More information and specific instructions can be found in the VictronConnect manual: https://www.victronenergy.com/live/victronconnect:start.


9.3. Incorrect readings

9.3.1. Charge and discharge current are inverted

The charge current should be shown as a positive value. For example: 1.45A.

The discharge current should be shown as a negative value. For example: -1.45A.

If the charge and discharge currents are reversed, the negative power cables on the battery monitor must be swapped.




9.3.2. Incomplete current reading

The negatives of all the loads and the charge sources in the system must be connected to the system minus side of the shunt.

If the negative of a load or a charge source is connected directly to the negative battery terminal or the "battery minus" side on the shunt, their current will not flow through the battery monitor and will be excluded from the overall current reading and the state of charge reading.

The battery monitor will display a higher state of charge than the actual state of charge of the battery.



9.3.3. There is a current reading while no current flows

If there is a current reading while no current is flowing through the battery monitor, perform a zero current calibration [26] while all loads are turned off or set the current threshold [25].



9.3.4. Incorrect state of charge reading

An incorrect state of charge can be caused by a variety of reasons.

Incorrect battery settings

The following parameter(s) will have an effect on the state of charge calculations if they have been set up incorrectly:

- · Battery capacity.
- · Peukert exponent.
- · Charge efficiency factor.

Incorrect state of charge due to a synchronisation issue:

The state of charge is a calculated value and will need to be reset (synchronised) every now and then.

The synchronisation process is automatic and is performed each time the battery is fully charged. The battery monitor determines that the battery is fully charged when all 3 "charged" conditions have been met. The "charged" conditions are:

- · Charged voltage (Voltage).
- Tail current (% of battery capacity).
- · Charge detection time (minutes).

A practical example of the conditions that need to be met before a synchronisation will take place:

- The battery voltage has to be above 13.8V.
- The charge current has to be less than 0.04 x battery capacity (Ah). For a 200Ah battery, this is 0.04 x 200 = 8A.
- · Both above conditions have to be stable for 3 minutes.

If the battery is not fully charged or if the automatic synchronisation does not happen, the state of charge value will start to drift and will eventually not represent the actual state of charge of the battery.

The following parameter(s) will have an effect on automatic synchronisation if they have been set incorrectly:

- · Charged voltage.
- Tail current.
- · Charged detection time.
- · Not occasionally fully charging the battery.

For more information on these parameters see the chapter: "Battery settings".

Incorrect state of charge due to incorrect current reading:

The state of charge is calculated by looking at how much current flows in and out of the battery. If the current reading is incorrect, the state of charge will also be incorrect. See paragraph Incomplete current reading [37].

9.3.5. State of charge is missing

This means that the battery monitor is in an unsynchronised state. This can occur when the battery monitor has just been installed or after it has been unpowered for some time and is being powered up again.

To fix this, fully charge the battery. Once the battery is close to a full charge, the battery monitor should synchronise automatically. If that doesn't work, review the synchronisation settings.

If you know the battery is fully charged but don't want to wait until the battery synchronises, then perform a manual synchronisation, see paragraph Synchronise SoC to 100% [26].

9.3.6. State of charge does not reach 100%

The battery monitor will automatically synchronise and reset the state of charge to 100% as soon as the battery has been fully charged. In case the battery monitor does not reach a 100% sate of charge, do the following:

- · Fully charge the battery and check if the battery monitor correctly detects if the battery is fully charged.
- If the battery monitor does not detect that the battery has been fully charged you will need to check or adjust the charged voltage, tail current and/or charged time settings. For more information see Automatic synchronisation [19].



9.3.7. State of charge always shows 100%

One reason could be that the negative cables going in and out of the battery monitor have been wired the wrong way around, see Charge and discharge current are inverted [36].

9.3.8. State of charge does not increase fast enough or too fast when charging

This can happen when the battery monitor thinks the battery is bigger or smaller than in reality. Check if the battery capacity [13] has been set correctly.

9.3.9. Incorrect battery voltage reading

Check if there is an issue with the +B1 cable. Perhaps the fuse, the cable itself or one of the terminals is faulty or there is a loose connection.

Check for incorrect wiring: the +B1 cable has to be connected to the positive of the battery bank, not midway of the battery bank.

9.3.10. Synchronisation issues

If the battery monitor does not synchronise automatically, one possibility could be that the battery never reaches a fully charged state. Fully charge the battery and see if the state of charge eventually indicates 100%.

Another possibility is that the charged voltage setting [24] should be lowered and/or the tail current setting [24] should be increased.

It is also possible that the battery monitor synchronises too early. This can happen in solar systems or in systems that have fluctuating charge currents. If this is the case change the following settings:

- Increase the "charged voltage [24]" to slightly below the absorption charge voltage. For example: 14.2V in case of 14.4V absorption voltage (for a 12V battery).
- Increase the "charged detection time [24]" and/or decrease the "tail current [24]" to prevent an early reset due to passing clouds.



10. Technical data


10.1. Technical data

Battery monitor	BMV-700	
Supply voltage range	6.5 - 95 Vdc	
Current draw (backlight off)	< 4mA	
Battery capacity (Ah)	1 - 9999Ah	
Operating temperature range	-40 +50°C (-40 - 120°F)	
VE.Direct communication port	Yes	
Relay	60V / 1A normally open (function can be inverted)	
RESOLUTION & ACCURACY (with a 500A	shunt)	
Current	± 0.01A	
Voltage	± 0.01V	
Amp hours	± 0.1Ah	
State of charge (0 - 100%)	± 0.1%	
Time-to-go	± 1 min	
Accuracy of current measurement	± 0.4%	
Accuracy of voltage measurement	± 0.3%	
INSTALLATION & DIMENSIONS		
Installation	Flush mount	
Head unit front diameter	63mm (2.5 inch)	
Head unit front bezel	69 x 69mm (2.7 x 2.7 inch)	
Head unit body diameter and depth	52mm (2.0 inch) and 31mm (1.2 inch)	
Shunt connection bolts	M10 (0.3937 inch)	
Head unit protection category	IP55 (not intended for outdoor use)	
STANDARDS		
Safety	EN 60335-1	
Emission / Immunity	EN 55014-1 / EN 55014-2	
Automotive	ECE R10-4 / EN 50498	
ACCESSORIES		
Shunt (included)	500A / 50mV	
Cables (included)	10 meter 6 core UTP with RJ12 connectors.	
	1 cable with 1A slow blow fuse for the battery positive connection.	
Temperature sensor	Optional (ASS000100000)	



11. Appendix

11.1. Dimensions BMV head unit





11.2. Dimensions shunt

